

ADDENDUM 4
RFP 13-14-008
Water Well Repairs
July 14, 2014

In reference to the above Invitation for Proposal, please note the following additional information:

The RFP has been extended to July 22, 2014 at 2PM.
Please see questions and answers below.

1. General Questions and Recommendation
 - a. Have all pumps been pulled from the wells listed? **No they have not.**
 - b. Can you provide two companies for vibration and well production testing? **We do not have a list of vibration and well testing companies. This usually sub-contracted.**
 - c. Can the City provide detailed well construction data? **Yes we can-See attachment.**
 - d. Will construction water be provided by the City? **Yes if the water is available at the site. If not the contractor will have to supply the water. Most of the wells have potable water available.**
 - e. Explain the City of Galveston specifications for disposal of acid, acid agitation and chlorine airlifting? **Disposal of the acid will be to neutralize the acid and dispose of at a proper disposal site and manifested as a non-hazardous waste. The acid agitation and airlifting must be compliant with AWWA Standards.**
 - f. Is the City of Galveston or contractor responsible for all electrical connections? **The City will provide an electrical contractor.**
 - g. Please clarify invoicing and payment terms? **All invoices shall be submitted to Wendy Zieseemer at 823 Rosenberg, Galveston Texas 77553, and full details can be disclosed by contacting her at 409-797-3630**
 - h. What are the bonding requirements? **The Bonding requirements will be dictated by Legal and/or Purchasing at the time of negotiation.**
 - i. Please clarify what 15% contingency means? **15% of the complete job for unforeseen issues during rehabilitation.**
 - j. Will standard fabricated steel discharge head equipped with a nonadjustable column be accepted? **Yes**
 - k. Motor clarification. **Please supply a 350HP Motor.**

If you have any questions, please call me at (409) 797-3575.

Tifney Scott
Purchasing Supervisor
City of Galveston, TX.

I hereby certify receipt of this addendum and have incorporated its information or changes in preparation of my submittal.

Authorized Signature

Date

Printed Name

Company Name

A COPY OF THE ADDENDUM MUST BE RETURNED WITH YOUR BID!